

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO: 3240-0447:120 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: ESL/Sentrol, 12345 SW Levetron Drive, Tualatin, OR 97062
Contact: Gene Hukkanen (503) 691-7369

DESIGN: Model 609U series bases and one of the following function cards: 609U10 through 609U14, 609U21 through 609U25 or 609U31 through 609U34. Suitable for use in HVAC ducts. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a detector base for use with Model 611UD photoelectric duct detector (CSFM Listing No. 7272-0447:114) or Model 612UD ionization detector (CSFM Listing No. 7271-0047:116).

NOTE: Formerly 3243-0447:120

07-12-93



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 2, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager